

EU-25-2368 Single Party Framework agreement for the Supply, Delivery, Commission and Maintenance of Emergency Generators to Local Authorities across the Republic of Ireland.

Response to Queries/ Clarifications

Ref	Date Received	Query/ Clarification	Response to Vendor Query	Date Issued
1	06/10/2025	If ATC is ready to be connected from customer's each sites for canopies provided by supplier	Any connections to the ATS will be completed by others. Genset skids will be delivered to 31 sites by the appointed supplier and will be installed by the individual Local Authorities after applicable emergency sites are identified. Any canopy for the ATS will be by others and does not form part of this procurement.	15/10/2025
2	06/10/2025	30 kVA or 100 kVA required for trailer, if so does the stage V engine required	There is <u>no requirement</u> for Stage V engines for either generator. Each generator is considered to be a fixed stationary unit used for standby emergency power.	15/10/2025
3	06/10/2025	If fixed stationary canopies in question, which party takes care of foundation to canopies, connection of cabling to ATS /distribution panel, construction work of grounding and external cablings etc	Foundations & cabling to/from gensets will be provided by others at each site as required. There is no installation scope by the Suppliers under this competition	15/10/2025