




Corracreigh-Peake Mantua Amalgamation Site Investigation						Trial Pit No TP001		
Project Name: <i>Corracreigh-Peake Mantua Amalgamation</i>			Project No. <i>CORRPEAK-001</i>		Co-ords: 578337.573,785524.116 Level:		Date <i>15/11/2023</i>	
Location: <i>Co. Roscommon</i> Client: <i>Roscommon County Council</i>					Dimensions: Depth 1.2m 1.0m 1.0m		Scale <i>N/A</i>	
							Logged By <i>FQ</i>	
Samples & In Situ Testing				Level (m AOD)	Depth (m)	Stratum Description	Legend	
Water	Depth (m)	Type	Results					
					0.150	Topsoil: Firm, brown, slightly sandy gravelly SILT. Gravel is fine to coarse, subangular.		
					0.800	Soft to firm, brown, slightly sandy slightly gravelly SILT. Sand is fine to coarse. Gravel is fine to medium, subangular.		
					1.200	Firm, stiff with depth, Firm, brown, very gravelly SILT with some cobbles and occasional boulders. Gravel is fine to coarse, subangular. Cobbles are subrounded, 60 to 120mm dia. Boulders are subrounded, 200 to 250mm dia.		
						Trial pit completed at 1.2 m		
Water	Depth(m)	Type	Results	Level	Depth			
Stability: Good Plant: Tracked Excavator Backfill: Arisings						Groundwater : None encountered		
Remarks:								



Trial Pit Location Map

Trial Pit Photographic Record



Number: TP 001

Project Corracreigh-Peake Mantua Amalgamation
Project No CORRPEAK-001
Client RCC
Engineer



Number: TP 001

Project Corracreigh-Peake Mantua Amalgamation
Project No CORRPEAK-001
Client RCC
Engineer