

### Security Device Schedule

| Description                         | Manufacturer | Model | Count |
|-------------------------------------|--------------|-------|-------|
| Ceiling Mounted CCTV Dome Camera    |              |       | 2     |
| Green Break Glass Unit              |              |       | 3     |
| Intercom                            |              |       | 1     |
| Intercom Handset                    |              |       | 2     |
| Intruder Alarm Panel                |              |       | 1     |
| Intruder PIR                        |              |       | 6     |
| Kaba Door Lock                      |              |       | 4     |
| Keypad                              |              |       | 4     |
| Magnetic Contact                    |              |       | 18    |
| Push Button                         |              |       | 1     |
| Wall Mounted CCTV Bullet Camera     |              |       | 6     |
| Wall Mounted Intruder Alarm Sounder |              |       | 1     |

### General Notes:

- This drawing is to be read in conjunction with all relevant Architect's and Structural Engineer's Construction issued drawings, Fire Certificate and Fire Drawings, along with the consultants Mechanical and Electrical specifications and any other documentation.
- Do not scale from this drawings.
- This drawing is representative only. All dimensions are in millimeters (mm), unless otherwise stated. Use the figured dimensions when shown.
- The exact location of all services and fittings to be agreed on site with the Architect and/or Structural Engineer prior to their installation.
- The Mechanical and Electrical Services are to be coordinated with all other trades and to be agreed on site prior to their installation. The contractor shall allow for the setting out and installation around all obstructions. Additional costs incurred by the contractor due to the lack of coordination will not be entertained.
- Connections to all equipment to be made by the contractor.
- Any discrepancies between this drawing and on site conditions must be reported to Renaissance Engineering LTD. immediately. Any changes from this design drawing must be agreed with the Engineer in writing. A failure to gain this approval could lead to difficulty in approving payment for the variation(s).
- Installation / Construction / As-Built Drawings to be prepared by the Mechanical/Electrical Contractor with reference to the latest Architect's and Structural Engineer's construction issue drawings and fire certificate drawings.
- All Electrical works to comply with the National Rules for Electrical Installations, 5th Edition IS 10101:2020.
- All Mechanical and Electrical works to comply with the current Building Regulations.

### Legend

|  |                                     |
|--|-------------------------------------|
|  | Alarm Reset Button                  |
|  | Ceiling Mounted CCTV Dome Camera    |
|  | Control Panel                       |
|  | Distribution Board                  |
|  | Fire Alarm Control Panel            |
|  | Green Break Glass Unit              |
|  | Indicator Light                     |
|  | Intercom                            |
|  | Intercom Handset                    |
|  | Intruder Alarm Panel                |
|  | Intruder PIR                        |
|  | Kaba Door Lock                      |
|  | Keypad                              |
|  | Magnetic Contact                    |
|  | Pullcord                            |
|  | Push Button                         |
|  | Wall Mounted CCTV Bullet Camera     |
|  | Wall Mounted Intruder Alarm Sounder |



|     |            |                      |      |        |
|-----|------------|----------------------|------|--------|
|     |            |                      |      |        |
|     |            |                      |      |        |
| P   | 2025/02/12 | Initial Revision     | A.B. | B.S.   |
| Rev | Date       | Revision Description | Dm.  | Chk'd. |



Address : 2nd Floor, 67-70 Meath Street, Dublin 8, D08 YCK4, Ireland  
Telephone : +353 (0)1 675 0850  
Email : info@reng.ie  
Web : renaissanceengineering.ie

Status Code:

**D2 - Issued for Tender**

Client:

**To Be Captured**

Architect:

**Haslam & Co Architects**

Project Name:

**Cherry Orchard Community Childcare Expansion**

Sheet Name:

**Protective Services  
Ground Floor**

Scale:

**1 : 50**

Document Number:

**24276-REN-XX-GF-DR-E-6800**

Revision:

**P**

Approved By:

Revit Filename:

**24276-REN-ZZ-ZZ-M3-ME-0001-Model.rvt**

Drawing revision legend: P = Pre-Contract, C = Contract

Internal Project Number : 24-276

**1**

Protective Services - Ground Floor

1 : 50

100mm - Caution when scaling - Please Check