GROUND FLOOR LAYOUT

GENERAL NOTES:

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH CONSULTING ENGINEERS' MECHANICAL AND ELECTRICAL SPECIFICATIONS AND EQUIPMENT SCHEDULES, ARCHITECTS AND STRUCTURAL ENGINEER DRAWINGS AND SPECIFICATIONS.
2. INSTALLATION SHALL COMPLY WITH BUILDING REGULATIONS, RELEVANT STANDARDS, INSTITUTE OF PLUMBERS DESIGN GUIDE AND MANUFACTURER'S REQUIREMENTS AND RECOMMENDATIONS.

SURVEY NOTES:

1. ELECTRICAL CONTRACTOR TO CARRY OUT A SURVEY ON THE EXISTING LIGHTING CIRCUITS WITHIN THE FACILITY ON EACH ELECTRICAL DISTRIBUTION BOARD.
2. ALL LIGHTS ARE TO SWITCHED ON AND THE RUNNING CURRENT IS TO BE MEASURED AND RECORDED IN TABLE FORMAT BEFORE ANY WORK COMMENCES.
3. UPON COMPLETION OF THE WORKS THE ELECTRICAL CONTRACTOR IS TO CARRY OUT THIS PROCESS AGAIN AND RECORD THE FINDINGS IN THE ABOVE TABLE.
4. THE COMPLETED TABLE IS TO BE PROVIDED TO THE CLIENT AS PART OF THE HANDOVER PACK IN EXCEL FORMAT TO FACILITATE THE CLIENT TO IDENTIFY AND CALCULATE SAVINGS IN POWER CONSUMPTION ACHIEVED BY THESE WORKS.

INSTALL NOTES:

1. IMPACT RESISTANT LIGHT FITTINGS TO BE INSTALLED IN ALL WORKSHOPS.
2. 5No. ADDITIONAL LIGHT FITTINGS OF EACH TYPE TO BE INCLUDED FOR FUTURE USE/SPARES.
3. EXISTING CARPARK LIGHTING TO BE REPLACED WITH NEW LED'S

LEGEND:

- 600mm x 600mm MODULAR LED LUMINARE (EXISTING)
- 1200mm x 600mm MODULAR LED LUMINARE (EXISTING)
- 1200mm x 300mm MODULAR LED LUMINARE (EXISTING)
- PENDANT LUMINARE (EXISTING)
- LOW LUX BULKHEAD SPOTLIGHT (EXISTING)
- SURFACE MOUNTED CIRCULAR LUMINARE (EXISTING)
- 600mm x 600mm MODULAR LED LUMINARE
- 1200mm x 600mm MODULAR LED LUMINARE
- 1200mm x 300mm MODULAR LED LUMINARE (SURFACE – TYPE AS APPROPRIATE)
- PENDANT LUMINARE
- LOW LUX BULKHEAD SPOTLIGHT
- SURFACE MOUNTED CIRCULAR LUMINARE
- WALL MOUNTED EXTERNAL LUMINARE
- PASSIVE INFRA RED LIGHTING
- WALL MOUNTED INTERNAL LUMINARE
- EMERGENCY EXIT LIGHTING

DO NOT SCALE FROM THIS DRAWING. USE FIGURED DIMENSIONS IN ALL CASES. VERIFY DIMENSIONS ON SITE AND REPORT ANY DISCREPANCIES TO THE ARCHITECTS IMMEDIATELY.
THIS DRAWING TO BE READ IN CONJUNCTION WITH THE ARCHITECTS SPECIFICATION.
THIS DRAWING IS COPYRIGHT AND MAY ONLY BE REPRODUCED WITH THE ARCHITECTS PERMISSION.
THIS DRAWING IS TO BE USED ONLY FOR THE RELEVANT WORKSTAGE DESCRIBED IN THE TITLEBAR AND SHOULD NOT BE RELIED ON FOR ANY OTHER PURPOSE WHATSOEVER

NOTES

REV	REV DATE	BY	REV NOTES
B	24/04/26	FD	EMERGENCY EXIT LIGHTS ADDED

DRG. SERIES

WIECS Engineering Ltd T/A
Doran Professional Services
Consulting Engineers
Bohoh, Lisaweasy, Kilsallagh
Westport, Co. Mayo
T 087247929
email forgusdoran@gmail.com

CLIENT
MSLETB

PROJECT
TRAINING CENTRE
BALLYTIVNAN, SLIGO

DRAWING
GROUND FLOOR
LIGHTING LAYOUT

Date	27/04/26	SCALE:	1:150	STAGE:	
DRN	ROC	CHECKED	JS	ISSUE:	FOR APPROVAL
JOB CODE	M6039	DWG NUMBER	63_G01	REVISION	B

MSLETB-STC-LED-0