

Indoor ref	Floor	Room Name	Area	Min. Heigh	Max. Heigh	Volume (m	Floor Area	Floor Perim	Heating	Heating	MODEL NUMBER	HEATING	COOLING	CURRENT	RATING	OUTDOOR REF	MODEL	CURRENT	FUSE RATING	VOLTAGE	Heating	Cooling
			m2						w/m2	Required		Watts	Watts	Amps	Amps			A	A	V	Scop	SSEER
IU-01	First	RF-21 LETTABLE OFFICE	59	3	5.75	312.282	58.732	45.86	80	4720	PLFY-M40VEM6-E	5000	3790	0.32	6	OU-01	PURY-EM450YSXM-A	30.3	40	400	4.45	7.82
IU-02	First	RF-20 LANDLORD OFFICE	34.8	3			36.67		80	2784	PLFY-P25VFM-E	3200	2380	0.22	6							
IU-03	First	RF-15 LETTABLE OFFICE	30.1	3	5.75	89	30.14	23.34	80	2408	PLFY-P25VFM-E	3200	2380	0.22	6							
IU-04	First	RF-18 LETTABLE OFFICE	15.9	3	5.75	145.054	16.67	29.79	80	1272	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-05	First	RF-17 LETTABLE OFFICE	28.7	3			28.59		80	2296	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-06	First	RF-22B LETTABLE OFFICE	35.8	3	5.75	99.575	36.46	25.08	80	2864	PLFY-P25VFM-E	3200	2380	0.22	6							
IU-07	First	RF-16 LETTABLE OFFICE	30	3	5.75	87.664	30.14	23.2	80	2400	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-08	First	RF-22A LETTABLE OFFICE	66.7	3	5.75	184.895	67.34	34.01	80	5336	PLFY-P50VEM6-E	6300	4030	0.32	6							
IU-09	First	RF-26 BOARDROOM	44.5	3	5.75	142.123	44.51	29.53	80	3560	PLFY-M32VEM6-E	4000	3110	0.32	6							
IU-10	First	RF-12 LETTABLE OFFICE	21.7	3	5.75	64.294	21.71	20.84	80	1736	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-11	First	RF-13 LETTABLE OFFICE	30.1	3	5.75	88.404	30.14	23.29	80	2408	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-12	First	RF-14 LETTABLE OFFICE	30.1	3	5.75	88.412	30.14	23.28	80	2408	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-13	First	RF-27 CANTEEN	34.5	3	5.75	71.044	33.88	20.84	80	2760	PLFY-P25VFM-E	3200	2380	0.22	6							
IU-14	First	RF-25 LETTABLE OFFICE	19.8	3	5.75	58.062	19.86	18.65	80	1584	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-15	First	RF-24 LETTABLE OFFICE	22.5	3	5.75	67.672	22.51	19.93	80	1800	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-16	First	RF-23 LETTABLE OFFICE	22.5	3	5.75	67.398	22.51	19.89	80	1800	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-17	Ground	RG-18 LETTABLE OFFICE	30.1	0	3	97.092	30.15	23.34	80	2408	PLFY-P25VFM-E	3200	2380	0.22	6	OU-02	PURY-EM400YSXM-A	10.7	20	400	4.7	8.65
IU-18	Ground	RG-25 COFFEE DOCK	14.1						80	1128	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-19	Ground	RG-08A LETTABLE OFFICE	65.5	0	3	42.571	12.14	15.61	80	2620	PLFY-P25VFM-E	3200	2380	0.22	6							
IU-20	Ground	RG-08A LETTABLE OFFICE		0	3	89.416	26.18	22.07		2620	PLFY-P25VFM-E	3200	2380	0.22	6							
IU-21	Ground	RG-03 RECEPTION	8.4						80	672	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-22	Ground	RG-07 LETTABLE OFFICE	22.5	0	3	75.231	22.51	20.12	80	1800	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-23	Ground	RG-04 LETTABLE OFFICE	23.6	0	3	73.545	22.32	19.9	80	1888	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-24	Ground	RG-05 LETTABLE OFFICE	14.7	0	3	49.33	14.77	16.93	80	1176	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-25	Ground	RG-15 LETTABLE OFFICE	15.9	0	3	113.878	39.34	26.4	80	1272	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-26	Ground	RG-16 LETTABLE OFFICE	28.7	0	3	157.967	16.67	29.79	80	2296	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-27	Ground	RG-20 LETTABLE OFFICE	52.8	0	3	166.579	52.85	29.83	80	4224	PLFY-M32VEM6-E	4000	3110	0.32	6							
IU-28	Ground	RG-19 LETTABLE OFFICE	30	0	3	96.45	30.15	23.29	80	2400	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-29	Ground	RG-17 LETTABLE OFFICE	30	0	3	95.633	30.14	23.2	80	2400	PLFY-P20VFM-E	2500	1940	0.32	6							
IU-30	Ground	RG-06 LETTABLE OFFICE	22.5	0	3	73.191	22.51	19.85	80	1800	PLFY-P15VFM-E	1900	1480	0.32	6							
IU-31	Ground	RG-01 MAIN LOBBY	54.6				54.01		80	4368	PLFY-M40VEM6-E	5000	3790	0.32	6							
IU-33	Ground	RG-09 MEDIA ROOM	84.5						80	6760	PLFY-M63VEM6-E	8000	5100	0.32	6							
IU-32	First	RF-30 COMMS		3	5.75	22.836	8.304	11.7		664.32	MSZ-HR50VF		4960	0.6	6	OU-03	MUZ-HR50VF2	5.9	10	230	4.3	6.5