

ESBN 125MM DUCT TO METERED
CUSTOMER PILLAR WHICH HOUSES
ESBN KW METER AND MDB
ALSO SEE UTILITIES DRAWING

ALL CONDUITS ETC TO BE ENCASED IN THE
CONCRETE BEFORE POURING. NO
CHASING ALLOWED. SEE SPECIFICATIONS
FOR FURTHER INFORMATION.
END OF CONDUITS TO BE CAPPED AS TO
PREVENT CONCRETE BLOCKAGES.

ALL ELECTRICAL EQUIPMENT AND WIRING
ACCESSORIES TO BE MOUNTED A MINIMUM
OF 1000MM ABOVE FFL WHERE POSSIBLE
FOR FLOOD RISK MANAGEMENT.

ALL SYSTEMS ARE TO BE CAPABLE OF
BEING FULLY DRAINED WHERE FREEZING
TEMPERATURES COULD CAUSE DAMAGE
TO PIPES AND EQUIPMENT.

WATERMAIN TO COUNCIL METER AS
PER CIVILS DRAWING

OPEN EIR 100MM DUCT TO OPEN EIR
MANHOLE
ALSO SEE UTILITIES DRAWING

