



20260717-058_A0

BLACK - 38KV & HIGHER VOLTAGE OVERHEAD LINES
GREEN - MV(10KV/20KV) OVERHEAD LINES
BLUE - LV (400V/230V) OVERHEAD LINES
CYAN - 38KV & HIGHER VOLTAGE UNDERGROUND CABLE ROUTES
RED - MV/LV (10KV/20KV/400V/230V) UNDERGROUND CABLE ROUTES

** SCALE: 1:1000

** SCALE WHEN PRINTED ON AN A0 PAGE
XY COORDINATES DISPLAYED IN IRISH GRID COORDINATE
SYSTEM

Maps reproduced by permission:
© Tailte Éireann. All rights reserved, Licence No. CYAL50441214

THIS MAP INDICATES THE APPROXIMATE LOCATION OF ESB TRANSMISSION (400KV, 220KV, 110KV, 38KV) AND DISTRIBUTION (20KV, 10KV, 230V/400V) UNDERGROUND CABLES AND OVERHEAD LINES IN THE GENERAL AREA OF THE PROPOSED WORKS. ESB WORKS TAKE NO RESPONSIBILITY FOR THE ACCURACY OR COMPLETENESS OF THIS INFORMATION. THE INFORMATION IS PROVIDED FOR THE INFORMATION OF THE UNDERTAKER OF THE WORKS. THE LOCATION OF UNDERGROUND CABLES AND OVERHEAD LINES, LOW VOLTAGE (230V/400V) SERVICE CABLES (E.G. HOUSE SERVICES, FACTORY/SHOP SERVICES, PUBLIC LIGHTING LAMP SERVICES, ETC.) ARE NOT SHOWN ON THIS MAP. THE LOCATION OF UNDERGROUND CABLES MUST BE DETERMINED BY THE UNDERTAKER OF THE WORKS PRIOR TO ANY MECHANICAL EXCAVATION IS UNDERTAKEN. THE ACTUAL LOCATION OF ALL UNDERGROUND ELECTRICITY CABLES MUST BE ESTABLISHED AND VERIFIED ON THE SITE USING:

- (A) UP-TO-DATE MAP RECORDS;
- (B) CABLE LOCATOR EQUIPMENT OPERATED IN BOTH POWER AND RADIO MODES;
- (C) MANUAL HAND DIGGING OF TRIAL HOLES USING SAFE DIGGING PRACTICES.

REFER ALSO TO "ISA CODE OF PRACTICE FOR AVOIDING DAMAGE FROM UNDERGROUND SERVICES".

THE UNDERTAKER OF THE WORKS SHALL BE RESPONSIBLE FOR ANY DAMAGE, INJURY/DEATH OR LOSS OF SUPPLY AS A RESULT OF DAMAGE OR INTERFERENCE WITH ITS NETWORKS.

X,Y: 159326 , 163967

HIGH VOLTAGE

IF YOU INTEND WORKING, OR UNDERTAKING DEVELOPMENT WITHIN A CORRIDOR EXTENDING 40 METRES ON EITHER SIDE OF ANY HIGH VOLTAGE OVERHEAD LINES OR WITHIN A CORRIDOR EXTENDING 5 METRES ON EITHER SIDE OF ANY HIGH VOLTAGE UNDERGROUND CABLES YOU MUST CONTACT ESB NETWORKS IN ADVANCE OF WORKS AT 1800 372 757 OR EMAIL DIG@ESB.IE TO AGREE SAFE WORKING PROCEDURES AND NECESSARY CLEARANCES BETWEEN THE LINES AND THE DEVELOPMENT IN ADVANCE OF ANY EXCAVATION.

X,Y: 159326 , 163198