

Asbestos Register

(Page 1 of 1)

Client: The Office of Public Works Health & Safety Unit 51 St. Stephen's Green, Dublin 2	Site Location: C.T.I. Raheen Road Clonmel County Tipperary Roll Number: 72420E	Survey Date: 22.07.2010 Surveyor: Ashley Johnston
--	--	--

Site Ref Number	Area Surveyed	Location and Use of Material	Sample Reference	Asbestos Type	Condition	Material Assessment	Recommended Action	Priority Assessment
S01	Prep Room	Boarding to Rear of Fume Cupboard	NI000018	Chrysotile	Low Damage	4	Remove	1
S03	Science Classroom	Green Floor Tile + Bitumen	NI000020	Chrysotile	Medium Damage	4	Remove	1
S04	Science Classroom	Beige Floor Tile + Bitumen	NI000021	Chrysotile	Medium Damage	4	Remove	1

Note that this Asbestos Register has been prepared and issued following the carrying out of a Refurbishment & Demolition (Type 3) Asbestos Survey of Specific Areas affected by Proposed Works to the School and requires to be read in conjunction with the Asbestos Survey Report.

Asbestos Register

(Page 1 of 1)

Client: The Office of Public Works Health & Safety Unit 51 St. Stephen's Green, Dublin 2	Site Location: C.T.I. The Mall Clonmel County Tipperary	Survey Date: 22.07.2010 Surveyor: Ashley Johnston
Roll Number: 72420E		

Site Ref Number	Area Surveyed	Location and Use of Material	Sample Reference	Asbestos Type	Condition	Material Assessment	Recommended Action	Priority Assessment
-----------------	---------------	------------------------------	------------------	---------------	-----------	---------------------	--------------------	---------------------

NONE OF THE SUSPECTED ASBESTOS CONTAINING MATERIALS SAMPLED DURING THE COURSE OF OUR SURVEY WERE FOUND TO CONTAIN ANY FORM OF ASBESTOS

Note that this Asbestos Register has been prepared and issued following the carrying out of a Refurbishment & Demolition (Type 3) Asbestos Survey of Specific Areas affected by Proposed Works to the School and requires to be read in conjunction with the Asbestos Survey Report.

