



General Notes :

1. No part of this document may be re-produced or transmitted in any form or stored in any retrieval system without the written permission of the Consulting Engineer, David Kelly Paterson, as copyright holder except as agreed in writing on the project for which the document was originally issued.
2. The contractor is responsible for checking all levels and dimensions on site and shall refer any discrepancies to the Engineer.
3. Only drawings issued for CONSTRUCTION shall be used for construction purposes.
4. Work to figured dimensions only. Do not scale print.
5. Check size of drawing sheet against dimension marks at bottom left hand corner of sheet.

REINFORCEMENT NOTES:

1. This drawing shall be read in conjunction with all relevant drawings.
2. Concrete grade to be C28/35.
3. For bar bending schedules refer to schedules nos. 801/01-02.
4. Minimum cover to all reinforcement to be as follows:

STRIP FOUNDATION- 50mm
PILE CAP- 75mm BOTTOM&SIDES, 50mm TOP
GROUND BEAM - 75mm BOTTOM, 50mm TOP&
SIDES
WALLS - 50mm

5. All concrete work to be in accordance with BS-EN1992 and all relevant standards.

T = Top
B = Bottom
EF = Each face
NF = Near face
FF = Far face

6. Minimum reinforcement laps to be as follows:

H12 – 600mm
H16 – 800mm
H20 – 1000mm
H25 – 1250mm

Rev : T2	Note :		
	Date : 06 MAY '26	Drawn : PN	Approved : JK
Rev : T1	Note :		
	Date : 08 APR. '26	Drawn : PN	Approved : JK



Nelson House, Emmet Place, 10 Ormonde Street,
Youghal, Co. Cork. Kilkenny.
t. +353 (0)24 92412 t. +353 (0)56 7801260
e. info@dkp.ie www.dkp.ie

Project :
TIPPERARY COUNTY COUNCIL:
CAHIR MARKET HOUSE BUSINESS CENTRE
THE SQUARE, CAHIR, CO. TIPPERARY

ARCHITECT: DEATON LYSAGHT ARCHITECTS

Title : FOUNDATION
RC DETAILS

Purpose of Issue :

TENDER	1:50 ; 1:25; 1:10
--------	-------------------

Project No. :

2018

Drawing No.	
-------------	--

801

Issue No. :

T