

CLARIFICATION 5

TEN2600141

**CfT for Construction of 44 Units at Lios na Ri,
Cootehill, Co. Cavan for Cavan County Council**

Query 1

The BoQ only allows for the intruder alarm to house type F. The electrical drawing shows wiring only for the intruder alarm to all house types. Please advise what we are to allow for.

Response Query 1

Please include for **wiring only** for all house types, including house type F (maisonettes).
