



LEGEND

- MIN. 60 MINUTE SEPARATION /COMPARTMENT WALLS / FLOORS
MIN. 30 MINUTE SEPARATION /COMPARTMENT WALLS / FLOORS

DENOTES ROUTES OF FIRE ESCAPE REGARDING TRAVEL DISTANCES IN ACCORDANCE WITH FIGURE 5 - FLAT WITH RESTRICTED TRAVEL DISTANCE.

MAXIMUM OCCUPANCY NUMBERS

FD30S
SC FIRE DOORSET 30 min DOOR
SC = SELF CLOSING

- BG BREAK GLASS UNIT
EXIT EMERGENCY EXIT SIGN
D EXIT DIRECTIONAL EMERGENCY EXIT SIGN
PB PANIC BARS (PUSH BAR TO OPEN)

- VP VISION PANEL
(999) MINIMUM CLEAR OPENING OF 1000mm

DENOTES PROPOSED SUPPLY ESB UNIT TO BE CONTAINED IN FIRE PROOF CABINET

FE FIRE EXTINGUISHER

- B FIRE BLANKET
S SMOKE DETECTION UNIT
A ALARM SOUNDER
E EMERGENCY LIGHTING (3 HR. MAINTAINED)

FINAL ESCAPE FROM BUILDING

'A' EXIT DESIGNATION

= Existing Accommodation

= Existing Walls

=Proposed Walls

rev date description draw checked

St Clare PS, Manorhamilton