

SAFE DIGGING: ESB NETWORKS

Prior to commencing work you are recommended to contact Central Site in order to locate possible cables in the vicinity of your excavation site:

https://www.esb.ie/esbnetworks/en/safety-environment/safe_digging.jsp

For the latest revisions to Standard Specifications for Ducts, Electrical Services Guidebook for Housing Schemes and other information please refer to:

https://www.esb.ie/esbnetworks/en/download_documents/builders_developers/specifications_duct.jsp

https://www.esb.ie/esbnetworks/en/safety-environment/safe_digging.jsp

https://www.esb.ie/esbnetworks/en/download_documents/builders_developers/specifications_duct.jsp

This drawing should be read in conjunction with the 'Electrical Services Guidebook' issued by ESB Networks

All Minipillars must have a VC2 vault installed immediately to the front

- MV STATION
- MV KIOSK
- LV MINIPILLAR
- VAULT
- NEW UG DUCT

1 X 125MM DUCT
107 M

1 X 125MM DUCT
107 M

X,Y: 188766 , 339196

X,Y: 189092 , 339196

Maps reproduced by permission:
© Tailte Éireann. All rights reserved. Licence No. CYAL50441214

