© Fahey O'Riordan Consulting Engineering Ltd
This drawing and design is Copyright of Fahey O'Riordan Consulting Engineering Ltd and must not be reproduced without their written consent. The drawing remains the property of the consultants.

NOTES:

1. THIS DRAWING IS INDICATIVE ONLY AND SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION & ALL OTHER RELEVANT DRAWINGS.
2. THIS DRAWING MUST NOT BE SCALED. WORK TO FIGURED & SITE OBTAINED DIMENSIONS ONLY.
3. THE MECHANICAL CONTRACTOR IS RESPONSIBLE FOR COMPLETING ALL BUILDERS WORK AS SPECIFIED IN THE TENDER DOCUMENTS INCLUDING OPENING UP CEILINGS, CORING OPES, MAKING GOOD AND REINSTATEMENT AND REDECORATION.
4. CONTRACTOR SHALL HEAVY DUTY LAY RAM BOARD IN ALL ROOMS TO PROTECT FLOORING FROM DAMAGE / STAINING FROM WATER LEAKS DURING STRIP OUT DEMOLITION WORKS AND NEW INSTALLATION WORKS.

ANNOTATIONS & LEGEND OF SYMBOLS

- INDICATES PIPEWORK RUN UNDER FLOOR
- INDICATES PIPEWORK RUN AT LOW LEVEL
- INDICATES PIPEWORK RUN AT HIGH LEVEL
- INDICATES PIPEWORK RUN IN ATTIC / CEILING VOID
- INDICATES RISE/DROP IN PIPEWORK
- "D.T.L.L." INDICATES "DROP TO LOW LEVEL"
- "F/A" INDICATES "FROM ABOVE"
- "T/A" INDICATES "TO ABOVE"
- "F/B" INDICATES "FROM BELOW"
- "A.P." ANCHOR POINT
- EXISTING RADIATOR TO BE REMOVED
- EH EXISTING ELECTRIC HEATER TO REMOVED
- DWH EXISTING DOMESTIC HOT WATER CYLINDER TO BE CAREFULLY REMOVED AND SALVAGED FOR FUTURE REINSTALLATION IN THE UPGRADED HEATING CENTRE

SHOWER / AWC
STORE
ASD CLASSROOM 2
ROOM 18
QUIET ROOM 2
ROOM 19b
QUIET ROOM 1
ROOM 19a
ELEC.
ASD CLASSROOM 1
ROOM 17
HOT WORK AREA
ART ROOM
ROOM 20
T/A
DRAIN DOWN AND REMOVE EXISTING PIPEWORK AND RADIATORS AND MAKE GOOD TO WALLS AND CEILINGS. REDECORATE WALLS AND CEILINGS TO MATCH EXISTING (TYPICAL)
DEMONSTRATION
ROOM 16
SPHE
ROOM 21
1st YEAR BOYS WC
ROOM 22
HEATING DISTRIBUTION PIPEWORK RUN UNDER STEPS
ASSUMED ROUTE OF THE EXISTING HEATING DISTRIBUTION PIPEWORK IN CEILING VOID
TEACHER'S
WORKROOM
ROOM 25
CLASSROOM
ROOM 24
CLASSROOM
ROOM 15
CLASSROOM
ROOM 13
OFFICE
ROOM 12
CLASSROOM
ROOM 26
CLASSROOM
ROOM 11
RTHL
REMOVE PREVIOUS BYPASS REPAIR WITH MULTI LAYER PIPEWORK
DTLL
CLASSROOM
ROOM 23
COMPUTER ROOM 1
ROOM 14 & 14a
STORE
ROOM 14c
STORE
ROOM 14b
CLASSROOM
ROOM 10
ROUTE OF THE EXISTING U/G LPHW PIPEWORK TO MAIN SCHOOL BUILDING. PIPEWORK TO BE RETAINED UNTIL NEW SYSTEM IS COMMISSIONED AND ALL ROOMS CHANGED OVER
CLASSROOM
ROOM 27
JUNIOR BOYS WC
MH-01
SHEET 1
MATCHLINE
2625-MH-01 SHEET 1
MH-01
SHEET 1

T1	REVISED TENDER ISSUE	LL	JF	JF	07/09/26
T0	TENDER ISSUE	LL	JF	JF	29/07/26
REV	DESCRIPTION	BY	CHK	APP	DATE

CLIENT:
LIMERICK AND CLARE EDUCATION AND TRAINING BOARD
CAPITAL PROCUREMENT SECTION
STATION ROAD, ENNIS, CO CLARE

CAMPUS:
SCARIFF COMMUNITY COLLEGE
DREWSBOROUGH, SCARIFF, Co CLARE V94 Y9W2

Fahey O'Riordan Consulting Engineers
SHANACLOGH, CAPPAWHITE, Co. TIPPERARY.
TEL: +353 (0) 62 75929
EMAIL: info@force.ie
WEB: www.force.ie

Project:
HEATING SERVICES UPGRADE & GAS CONVERSION EMERGENCY WORKS PROJECT 2026

Drawing Title:
EXISTING HEATING SERVICES LAYOUT AND PROPOSED STRIP OUT & DEMOLITIONS WORKS

Scale	Drawn	Checked	Approved	Date
1:100 @ A1	LL	JF	JF	29/07/2026
Project No. 2625	Type M	Drawing No. 2625-MH-01 SHEET 2		Revision T1

APPROVAL☐ INFORMATION☐ TENDER☒ CONTRACT☐ CONSTRUCTION☐