

Ventilation Requirements in Accordance with TGD F 2019

MCLA

Opening Areas in Windows Calculations

Project Name	Project Number	Room Name	Room Area (m²)	1/20 of room area	Min Requirement for Purge Ventilation (m²)	Opening Area of Proposed Windows
Kildangan NS	21 30	Mainstream Classroom 1	78	3.9	3.9	4.5
Kildangan NS	21 30	Changing Place	13	0.65	0.65	0.75
Kildangan NS	21 30	Office	19	0.95	0.95	1.8
Kildangan NS	21 30	SEN Classroom	73	3.65	3.65	3.65
Kildangan NS	21 30	Mainstream Classroom 2	74	3.7	3.7	5.4