

SCHEDULE 1: SITE SPECIFIC DETAILS

1. Customer Details:

Customer Name: PORT OF WATERFORD
TERMINAL LIM
Site Address: BELLEVUE, GYLES QUAY,
WATERFORD

2. Connection Agreement Number:

6008930958

3. Meter Point Details:

Meter Point Reference Number: 10 000 078 725

Metering Configuration Code: MCC10

DUoS Group: DG8

4. Characteristics of Connection:

Maximum Import Capacity (kVA): 750

Maximum Export Capacity (kVA): 0

Phase Rotation:

No. of Phases: RST

Connection Voltage (V): 38KV

Frequency (Hz): 50Hz

Minimum Equipment Short Circuit Rating (kA) ⁺:

Normal Short Circuit Level at Connection Point (MVA) [#]:

Embedded Generation (kVA): 0

Inverter Capacity (kVA):

Export Limiting Scheme (ELS) (kVA): N/A

5. Protection Settings:

6. Terminal Sub-Station Interest Required:

7. Design Bond Required:

8. Capacity Bond Required:

9. Site Specific Requirements:

Not Applicable.

⁺ Refer to Conditions Governing Connection to the Distribution System available on our website: www.esbnetworks.ie

[#] This is the current Short Circuit Level calculated under normal feeding arrangements.