PIPE WRAP



34 COMBUSTIBLE PIPE 40 TO 600 MM Ø CORED OPE IN SOLID WALL CONSTRUCTION
SCALE : 1:5



35 COMBUSTIBLE PIPE 40 TO 600 MM Ø PERFORMED OPE IN SOLID WALL CONSTRUCTION
SCALE : 1:5



36 COMBUSTIBLE PIPE 40 TO 600 MM Ø OPE IN STUD PARTITION
SCALE : 1:5



37 COMBUSTIBLE TRUNKING PASSING THROUGH FR BLOCK WALL
SCALE : 1:5



38 COMBUSTIBLE PIPE 40 TO 650 MM Ø CORED OPE IN SOLID WALL CONSTRUCTION
SCALE : 1:5



39 CABLE TRAY THROUGH SOLID WALL CONSTRUCTION LARGE OPE
SCALE : 1:5

40 CABLE TRAY THROUGH SOLID WALL CONSTRUCTION WITH INTUMESCENT PILLOW
SCALE : 1:5



41 COMBUSTIBLE PIPE THROUGH FLOOR SLAB
SCALE : 1:5

42 CABLE TRAY THROUGH SOLID WALL CONSTRUCTION SMALL OPE WITH INTUMESCENT PILLOW
SCALE : 1:5

43 NON COMBUSTIBLE PIPE THROUGH STUD PARTITION
SCALE : 1:5

44 CABLE TRAY THROUGH STUD PARTITION

45 FIRE DAMPER IN SOLID WALL CONSTRUCTION
SCALE : 1:5

46 FIRE SEALING GAPS OVER FIRE RATED PARTITIONS
SCALE : 1:5

47 FIRE DAMPER IN STUD PARTITION CONSTRUCTION
SCALE : 1:5

48 SMALL PIPE/CABLE SERVICES THROUGH FLOOR SLAB - NON LOAD BEARING FIRE STOPPING (SMALL OPES ONLY)
SCALE : 1:5

49 SERVICES THROUGH FLOOR SLAB - LOAD BEARING FIRE STOPPING (LARGE OPENING)
SCALE : 1:5

50 COMBUSTIBLE PIPE THROUGH CORED OPE IN FLOOR SLAB
SCALE : 1:5

DO NOT SCALE FROM THIS DRAWING

Copyright in all documents and drawings prepared by AFEC Engineering Ltd, and in any works executed from those documents and drawings shall remain the property of AFEC Engineering Ltd, unless otherwise agreed at project inception.

This drawing is to be read in conjunction with all relevant engineers & specialist drawings, specifications and contract documents. Work to figured dimensions only. All documents to be verified by the contractor on site. All discrepancies should be reported to the architect prior to commencement of the works.

NOTES

REV	DATE	DESCRIPTION	DRWN BY	CHKD BY	APPD BY
P01	14.08.2026	Issued for Tender	RB	DM	CG

AFEC International
Unit 1, Airport Logistics Park, Dublin, K67 N237
W - www.afec.ie E - admin@afec.ie P - 01 6642836

CLIENT: Respond Housing	AFEC JOB NO.: 24304
PROJECT: Fairhill Lodge	SCALE (@ A1): 1:5
DRAWING TITLE: Detail - Internal Wall Penetration Details	STATUS: D2
DRAWING NUMBER: 24304-AFEC-00-ZZ-DR-A-6004	REVISION: P01