



Hazard Identification and Risk Assessment
(Including Particular Risks & Other Significant Risks)

Job Number

4371

Page Number

1 of 3

Project	De La Salle Additional Accommodation Project			Design Issue or Element		School Extension				
Stage	Scheme Stage			Pre- Tender Stage			Other (Clarify)			
	Name	Initial	Date	Name	Initial	Date	Name	Initial	Date	
Designer	Thomas McGuinness DCE IRL	TMcG	10/11/2022	Thomas McGuinness	TMcG	30/09/2026				
Project Manager	Gary Barron DCE IRL	GB	10/11/2022	Gary Barron	GB	30/09/2026				
Hazard			Design Mitigation measures			Other Possible Mitigation Measures (including measures by Contractor on site)		Residual Risk Assessment following mitigation measures		
								Likelihood	Severity	Risk Rating
1.	Excavations		Trench boxes to be used where excavation is deeper than 1.5m. To be confirmed on site with DCE IRL					H	H	M
2.	Existing Services		All existing services to be identified by the Contractor and Design Team to be informed prior to works commencing. RAMS to be forwarded to PSDP and DT for review prior to works commencing on site.			The ground should be scanned prior to and during excavations.		H	H	M

Likelihood of Hazard occurring
L = Low (Seldom)
M = Medium (Reasonably Likely)
H = High (Certain/Nearly certain)

Severity of Harm
L = Minor Injury/Illness
M = Injury/Illness causing short term disability
H = Fatality or major injury/illness causing long term disability

Risk Assessment
L = Low Risk (No action)
M = Medium Risk (Action required unless good reason not to)
H = High Risk (Action required e.g. Design Change)

Refer to [Arup Health & Safety Designer's Handbook](#) and Detailed Design Project Flowchart for guidance on form sign off and issue to PSDP.

Risk Table	Severity		
Likelihood	H	M	L
H	H	H	M
M	H	M	L
L	M	L	L



Hazard Identification and Risk Assessment
(Including Particular Risks & Other Significant Risks)

Job Number

4371

Page Number

2 of 3

Project	De La Salle Additional Accommodation Project			Design Issue or Element	School Extension				
Stage	Scheme Stage			Pre- Tender Stage			Other (Clarify)		
	Name	Initial	Date	Name	Initial	Date	Name	Initial	Date
Designer	Thomas McGuinness DCE IRL	TMcG	10/11/2022	Thomas McGuinness	TMcG	30/09/2026			
Project Manager	Gary Barron DCE IRL	GB	10/11/2022	Gary Barron	GB	30/09/2026			
Hazard				Design Mitigation measures		Other Possible Mitigation Measures (including measures by Contractor on site)	Residual Risk Assessment following mitigation measures		
							Likelihood	Severity	Risk Rating
3.	Heavy Prefabricated Units			All heavy concrete and precast units & steel to be craned in. Method Statements for lifting all prefabricated items to be forwarded to the design team and the PSDP for review.			M	H	M
4.	Work adjacent to public roads and school			Public Road (Castletown Road) to be kept clear of debris. Contractor to provide Traffic Management Plan for the works adjacent to the public road. Access to the the rear of the school may also be required for Fire Tender. Further review required by PSDP to ensure access route is not blocked during construction phase		Area to be hoarded off to ensure the site and school are separated	M	H	L
5.	Construction Works			Site to be sealed off to the public during construction works. Areas to be left safe at all times.			M	H	H

Likelihood of Harm

L = Low (Seldom)
M = Medium (Reasonably Likely)
H = High (Certain/Nearly certain)

Severity of Harm

L = Minor Injury/Illness
M = Injury/Illness causing short term disability
H = Fatality or major injury/illness causing long term disability

Risk Assessment

L = Low Risk (No action)
M = Medium Risk (Action required unless good reason not to)
H = High Risk (Action required e.g. Design Change)



Hazard Identification and Risk Assessment
(Including Particular Risks & Other Significant Risks)

Job Number

4371

Page Number

3 of 3

Project	De La Salle Additional Accommodation Project			Design Issue or Element		School Extension				
Stage	Scheme Stage			Pre- Tender Stage			Other (Clarify)			
	Name	Initial	Date	Name	Initial	Date	Name	Initial	Date	
Designer	Thomas McGuinness DCE IRL	TMcG	10/11/2022	Thomas McGuinness	TMcG	30/09/2026				
Project Manager	Gary Barron DCE IRL	GB	10/11/2022	Gary Barron	GB	30/09/2026				
Hazard			Design Mitigation measures			Other Possible Mitigation Measures (including measures by Contractor on site)		Residual Risk Assessment following mitigation measures		
								Likelihood	Severity	Risk Rating
6	Fall From height		Working at height (All levels) Contractor to submit RAMS to PSDP for review prior to commencing work on site.					H	H	H

Likelihood of Harm

L = Low (Seldom)
M = Medium (Reasonably Likely)
H = High (Certain/Nearly certain)

Severity of Harm

L = Minor Injury/Illness
M = Injury/Illness causing short term disability
H = Fatality or major injury/illness causing long term disability

Risk Assessment

L = Low Risk (No action)
M = Medium Risk (Action required unless good reason not to)
H = High Risk (Action required e.g. Design Change)