



Comhairle Contae Lú
Louth County Council

McGahon Architects Ltd
13 Jocelyn St
Dundalk
Co Louth

10 December 2021

Re: Application for **Fire Safety Cert** in respect of **two storey extension including general school accommodation and ASD unit at De La Salle College, Bellewsbridge rd, Dundalk, Co Louth**

Premises ID D0270

Reference No. FA21/0090

A Chara

Please find enclosed **Fire Safety Cert** re above application.

Is mise le meas

A Parks
Fire & Building Control

cc: Board of Management

Enc.

Comhairle Contae Lú
Halla an Chontae
Ionad na Milaoise
Dún Dealgan
Contae Lú
A91 KFW6

Louth County Council
County Hall
Millennium Centre
Dundalk
County Louth
A91 KFW6

T + 353 42 9335457
F + 353 42 9334549
E info@louthcoco.ie
W www.louthcoco.ie

Cuirfear fáilte roimh-chomhfhreagras Gaeilge - Correspondence in Irish is welcome



Building Control Acts 1990 to 2014

Fire Safety Cert

Reference: FA21/0090

Date of issue: 10 December 2021

Applicant : Board of Management

Development Description : two storey extension including general school accommodation and ASD unit


Development Address : De La Salle College, Bellewsbridge rd, Dundalk, Co Louth

CE Order No: BC0260/21

Fire Safety Cert (FA21/0090) **Decision to Grant With Conditions**

Louth County Council hereby certifies that the building or works to which the application relates, will, if constructed in accordance with the plans, calculations, specifications and particulars submitted, comply with the requirements of Part B of the Second Schedule to the Building Regulations as amended. In considering the application, no assessment has been made as to whether the building or works will comply with the other requirements of the Second Schedule to the Building Regulations as amended. This certificate is **Granted With Conditions** subject to the schedule of conditions attached.

SIGNED:


JOE MCGUINNESS
DIRECTOR OF SERVICES

Date: 10 December 2021

To whom this function has been delegated in accordance with the provisions of Section 154 of the Local Government Act, 2001 by Order No. 277/19 dated 27th day of September 2019



Schedule of Conditions with Reasons

FA21/0090

1) The development shall be undertaken in accordance with the plans and particulars submitted on the 06 September 2021, and including the conditions attached below.

Reason: To comply with Part B1 – B5 of the Second Schedule to the Building Regulations, 1997 to 2020.

2) The fire detection and alarm system shall be designed, installed, serviced and maintained in accordance with **IS3218:2013 + A1:2019** *Fire Detection and Fire Alarm Systems for Buildings – System Design, Installation, Commissioning, Servicing and Maintenance*. A minimum category **L3** automatic detection system shall be provided. Certification in accordance with Annex D of **I.S. 3218:2013+ A1:2019** shall be kept available for inspection.

Reason: To satisfy requirement B1 (Means of escape in case of fire) of the Building Regulations, 1997 to 2020.

3) The emergency lighting system shall be designed, installed, commissioned, serviced and maintained in accordance with **IS3217:2013+A1:2017** *Emergency Lighting*. Appropriate certification in accordance with Annex C of **I.S. 3217:2013 + A1:2017** shall be kept available for inspection.

Reason: To satisfy requirement B1 (Means of escape in case of fire) of the Building Regulations, 1997 to 2020.

4) Portable fire extinguishers are to be provided in accordance with the recommendations of **I.S. 291:2015** *Selection, commissioning, installation, inspection and maintenance of portable fire extinguishers* and are to be manufactured to **I.S./EN 3-7 : 2004 + A1 2007**.

Reason: To satisfy requirement B1 (Means of escape in case of fire) of the Building Regulations, 1997 to 2020.

5) Fire door sets throughout the premises must meet the requirements of Appendix B of Technical Guidance Document B. Fire doors comprise the complete door assembly which includes the door leaf or leaves, the frame, ironmongery (hinges, latches, closers etc.) and any seals where required between the frame and the leaf or between leaves. Every fire door must be permanently identified in accordance with the recommendations of **BS 5499-10:2014**, as per Appendix B, Technical Guidance Document B. A test certificate for each fire door shall also be made available for inspection.

Reason: To satisfy requirement B1 (Means of escape in case of fire) of the Building Regulations, 1997 to 2020

6) Appropriate fire safety signage shall be installed throughout the premises and shall fully comply with Section 1.4.13, Technical Guidance Document B and SI 299 2007, Safety, Health and Welfare at Work (General Applications) Regulations 2007, Part 7.

Reason: To satisfy requirement B1 (Means of escape in case of fire) of the Building Regulations, 1997 to 2020.

7) The electrical installation shall be installed in accordance with the National Rules for Electrical Installations - Irish Standard 10101 : 2020 and/or equivalent approved.

Reason: To satisfy requirement B1 (Means of escape in case of fire) of the Building Regulations, 1997 to 2020.

8) The protection of openings from service penetrations in fire resisting elements of construction and provision of fire stopping material must be provided in accordance with the relevant requirements of Section 3.4, Technical Guidance Document B.

Reason: To satisfy requirement B3 (Internal Fire Spread Structure) of the Building Regulations, 1997 to 2020.

LOUTH COUNTY COUNCIL

FIRE SAFETY CERTIFICATES – APPEALS TO AN BORD PLEANALA

WHO MAY APPEAL?

Unlike planning decisions, where anyone can appeal, only the Applicant for a Fire safety Certificate can appeal to An Bord Pleanala if dissatisfied with a decision on an application or a condition attached to a FSC granted.

TIME LIMIT

An appeal must be received by the Board within a period of one month beginning on the date of the decision on the application, otherwise it will be invalid. Where the last day of this period falls on a Saturday, Sunday, public holiday or other day on which the offices of the Board are closed, the appeal will be in time if received on the next following day on which the Board's offices are open.

ADDRESS OF THE BOARD

An Bord Pleanala
64 Marlborough Street
Dublin 1
(Tel: 01 – 8588100)

HOW TO DELIVER AN APPEAL

An appeal must be sent by prepaid post to the Board at the above address or left with an employee of the Board at the Board's Offices during office hours.

CONTENT OF APPEAL

An appeal must be in writing and must contain the following particulars: -

- (a) Name and address of appellant (person appealing)
- (b) The subject matter of the appeal i.e. particulars of the application concerned including:
 - (i) Name of Applicant
 - (ii) Register Reference No.
 - (iii) Description and Location of Building, Works or Change of Use
 - (iv) Name of Building Control Authority
 - (v) Date of Decision

- (c) Full grounds of appeal and the reasons, considerations and arguments on which they are based. These must be fully stated at the outset and cannot be further elaborated on at a later stage.
-

APPEAL FEE

An appeal must be accompanied by the correct fee, otherwise it will be declared invalid. It is not sufficient to send the fee or part of it at a later stage. The appeal fee is €250.

TIME LIMIT FOR DECISION BY THE BOARD

The Board has the statutory objective to dispose of appeals within 4 months. If it does not consider it possible or appropriate to give a decision within four months in a particular case, it will notify all parties concerned and specify a new date by which it will give its decision.