

Tender Clarifications

Competition Reference		BE3917F - RFT for the Supply, Delivery, Installation and Support of a Campus Occupancy Sensing Solution for Trinity College Dublin (TCD)			
Issue Date		TBC			
Message ID e-tenders	Date Received	Query	Response	Response Date	Message ID e-tenders
808924	09.10.2026	Does the system that is being proposed need to have its data centre in the EEA, would it be acceptable to have a system with its data centre outside the EEA, namely in the UK?	Yes. Under Mandatory Requirement M2, the solution and all associated data must be hosted within the EU/EEA. Hosting in the United Kingdom, or elsewhere outside the EU/EEA, will not meet this requirement.	13.10.2026	
809761	12.10.2026	Would it be possible to confirm ceiling heights of for the rooms/theatres.	Measured ceiling heights are not available. For pricing purposes, tenderers should assume the following indicative heights: • Appendix A – Small Seminar Room: 2.7 m – 3.0 m • Appendix B – Standard Classroom: 2.7 m – 3.0 m • Appendix C – Large Lecture Theatre: raked seating with variable heights up to approx. 6.0 m; entrances 2.7 m – 3.0 m Tenderers should state the mounting height range of each proposed sensor. Final positions will be confirmed by site survey.	13.10.2026	
		Would it be possible for us to put forward two types of sensors to meet the requirements, both from the same vendor?	Yes. Tenderers may propose more than one sensor type, including from different manufacturers, provided each sensor type operates on a single platform and complies with all Mandatory, technical and network requirements. Tenderers must identify which sensor type is proposed for each space		

			(Appendices A–C) and price accordingly in Appendix 2. Suppliers please note: If you are proposing more than one sensor type, you must submit two (2) separate TRDs and two (2) separate Appendix 2 Pricing Schedules. Each submission should be clearly identified as Option A and Option B, as applicable.		