

LEGEND

- FACP


FIRE ALARM CONTROL PANEL
- FARP

FIRE ALARM REPEATER PANEL
- OPTICAL DETECTOR
- OPTICAL DETECTOR C/W SOUNDER BEACON BASE
- OPTICAL DETECTOR C/W SOUNDER BASE
- OPTICAL DETECTOR C/W BEACON BASE
- OPTICAL DETECTOR VOID CW REMOTE LED
- BREAK GLASS UNIT
- HEAT DETECTOR
- HEAT DETECTOR C/W SOUNDER BEACON BASE
- HEAT DETECTOR C/W SOUNDER BASE
- HEAT DETECTOR C/W BEACON BASE
- I/O UNIT
- EXTERNAL SOUNDER/BEACON
- Air-Sampling Unit

- Notes:
- All works to be compliant with IS3218:2024
  - Fire Alarm Panel - Advanced Pro5 Series with Hochiki Detection & Alarm devices
  - Final location of Fire alarm panel to be confirmed on site
  - Upgrade network to fault-tolerant type
  - All opes Firestopped as per specification
  - Final location of Interfaces for DHO's to be confirmed on site
  - Interfaces that are not required need not be installed



|          |      |         |                                        |
|----------|------|---------|----------------------------------------|
| REV. NO. | DATE | COMMENT | TITLE                                  |
|          |      |         | McBride MHU Westport                   |
|          |      |         | CLIENT: HSE                            |
|          |      |         | PROJ. NO.: TFS-HSE-MBMHU-001           |
|          |      |         | DESIGNER: R.D.                         |
|          |      |         | CHECKED: G.D.                          |
|          |      |         | PROJECT: Fire Detection & Alarm System |



Titan Fire Safety Ltd. Dun Eimear, Drogheda, Co. Louth  
Tel: 085 151 9509  
Email: ray@titanfiresafety.ie