

REFURBISHMENT OF GALLOWGLASS COMMUNITY CENTRE CO. DONEGAL
SCHEDULE OF LUMINAIRES

REFERENCE	DESCRIPTION	PHOTOGRAPH
REF A REF A/E	Ceiling Mounted AMEDSE L40 23.4W Dextra Amenity Decorative Secure IP65 Emergency fitting is lithium standard emergency 3 hour (LE3)	
REF B/E 3hour emergency version	Dextra Element Surface 1500mm Length ELS 15L50 – 27.2 W LED 3000K	
REF C/E	Thorn Voyager Solid L IP65 2.4W 165lm 6,500 K VOYAGER SOLID L MS E1/3-S WH	
Ref D	Decorative Wall Mounted Interior Lighting To be determined on site Allow 300EUR per fitting	

REFURBISHMENT OF GALLOWGLASS COMMUNITY CENTRE CO. DONEGAL
SCHEDULE OF LUMINAIRES

Ref E1	Lightsafe 3W LED Low Glare Non Maintained Emergency Twinspot with Self Test	
Re F/E	Thorn Lighting Xetaro Linear, emergency XETARO M 4400-840 MB HF E3 31W 4660lm 4,000 K	
Ref H	Outdoor Lighting Decorative Wall Mounted Exterior Lighting To be determined on site Allow 300EUR per fitting	
Ref I	Thorn The Chromix point CHP 50 06 RGBW GY MG Chromix Point 50W RGBW C84, 210mm Diameter, 6°, IP66, IK08, 48V complete with CHP SL - spread lens kit 10°/20°/30° 50.0W	

REFURBISHMENT OF GALLOWGLASS COMMUNITY CENTRE CO. DONEGAL
SCHEDULE OF LUMINAIRES

K/E	Dextra Eye Lid - amenity exterior Eyelid. IP65 L90>60hours 61lumens per circuit. c/w integral PIR R25 sensor-bright out facility and integral 3hour emergency invertor pack	
Exit Sign E2	Dextra HBE Maintained Exit sign. c/w self-test facility.	
Ref EX1 Ref EX2	Existing Decorative fittings to remain in halls, replace lamps with 21 W LED equivalent 3000K	

Note: Fittings indicated are for Illustration purposes only, alternatives can be offered as long as they meet the specification of each fitting indicated.

Wattage / lumen watt shall be equal or better than indicated