105.00m
100.00m
95.00m
90.00m
85.00m
80.00m
105.00m
New pipe laid to uniform grade
100.91m
pt 59
pt 62
SV4
100.74m
102.00m
101.00m
100.00m
100.00m
Pipe Laid to uniform grade
Top of Pipe =99.68m
600mm Concrete
Surface Water Pipe
I.L. = 98.86m
200mm PE 100, SDR 11 Water Main
99.00m
98.00m
97.00m
96.00m
95.00m
95.00m
90.00m
90.00m
85.00m
85.00m
24.80

gps Ref. point	pt 58				pt 59	pt 62				pt 63			pt 64	pt 66		pt 67	pt 68	pt 69	pt 72
Chainage {m}	ch 1275	ch 1300	ch 1325	ch 1350	ch 1375	ch 1400	ch 1425	ch 1450	ch 1475	ch 1500	ch 1525	ch 1550	ch 1575	ch 1600	ch 1625	ch 1650	ch 1675	ch 1700	
Ground Level to M.H.D. in meters	99.18	99.59	100.00	100.42	100.84	100.97	101.42	101.88	102.34	102.79	103.07	103.29	103.52	103.88	104.23	104.58	104.93	105.28	

Cross Section along the Route of the New Inn gws's New Rising Main Horizontal Scale 1 in 1250; Vertical Scale i in 125

John Diskin & Associates
Consulting Engineers
Stradbally North
Clarinbridge
County Galway
Ph No 091- 796071; 0872257118
Email : john@johndiskin.ie

PROJECT
Proposed New Pipeline for
The New Inn Group Water
Scheme in Rgional Road R348

DETAILS
Section of Route
of Proposed Pipe

USE OF THIS ORDNANCE SURVEY MAP
IS PERMITTED UNDER OSI LICENCE
CYAL50482695 and Galway Co Council
Licence CYAL 50510494

LEGEND
Proposed Water Main
Existing Watermain
SV Sluice Valve; AV Air valve; ScV scour valve

DRAWING TITLE
Section along Route of New Watermain

DRAWING No:
New Inn gws Section RM 2026_3_4

DRAWN BY
John Diskin BE, M.I.E.I.

Date: 29/09/2026

SCALE : 1/1250