A0



General Notes:

1. Do not scale drawings. Dimensions govern
2. All dimensions are in millimeters unless noted otherwise
3. All dimensions shall be verified on site before proceeding with the work
4. PTS shall be notified in writing of any discrepancies
5. Any areas indicated on this sheet are approximate and indicative only.

Specific Notes:

1. -

References:
-

Legend:

- RJ45 data outlet (Varying Qty's)
- Single Unswitched Fused connection unit
- Double Unswitched Fused connection unit
- Single Switched Socket Outlet
- Double Switched Socket Outlet
- 16A Commando Socket Outlet
- Fire Alarm Interface
- Lighting Interface
- Satellite TV Outlet
- Floorbox containing data and power quantities as shown
- Tablebox with grommet below. Data and power presented in floor void (quantities as shown)
- Tablebox with floorbox below containing data and power quantities as shown
- # 50x50mm twin compartment trunking in-wall from floor to ceiling void
- # Ø25mm Trunking in-wall from floor void to touch panel location
- AV Equipment Rack

Colour code
Blue = Low level M & E
Red = High level M & E
Green = Wall Mounted

Low level M & E Cable route (Min 30mm conduit)

High level M & E Cable route (Min 30mm cable tray)

Notes:

1. All AV and Data cables to be run separately to power
2. All Audio Visual equipment to be powered from the same electrical phase.
3. Final routes to be co-ordinated by Trade Contractors.

Rev	Date	Description	By	Check
P01	25/09/26	Issue for Coordination	JG	PR

Revisions/Status

Status Code
S3 - Suitable for Review and Comment

Client
Irish Department of Affairs

Project
Cork

Title
Level 01 AV Low-level M&E Requirements

Scale @ A0: 1:100
PTS project ref.: DFA-EU011
Drawn by: PA Date: 25/09/26
Checked by: PR Date: 25/09/26

PTS
Proudly employee owned.
16-18 Middlesex Street
London
E1 7EX

Tel: +44 (0)330 050 6200

e-mail: hello@pts.global
www.pts.global

Drawing no.: DFA-PTS-ZZ-01-DR-AV-3001
Revision: P01

Copyright © 2026 PTS Consulting Group Ltd Company registered in England: No. 01738788